

Fixed Ladder Safety Checklist

A fixed ladder is a ladder permanently attached to a structure, building, or equipment. Fixed ladders will normally be of a length greater than 20 ft (6.1 m) to a maximum unbroken length of 30 ft (9.1 m), and be equipped with cages or ladder safety devices. A "cage" is a guard that is fastened to the side rails of the fixed ladder, or to the structure, to encircle the climbing space of the ladder for the safety of the person climbing the ladder.

The primary hazard when using a ladder is falling. A poorly designed, maintained, or improperly used ladder may collapse under the load placed upon it and result in a fall. The following checklist can be used to evaluate the safety of fixed ladders:

	YES	NO	COMMENTS
Is the fixed ladder routinely cleaned and serviced?			
Are rungs kept free of grease, mud, or other slippery agents?			
Are metal ladders painted or treated to prevent corrosion or rust?			
Are wood ladders treated with a non-irritant preservative?			
If a cage is installed, does it extend a minimum of 42 in (107 cm) above the top of a landing?			
If a cage is installed, does it extend down the ladder to a point not less than 7 ft (2.13 m), or more than 8 ft (2.44 m), above the base of the ladder?			
Does the ladder include a safety device, other than a cage, such as life belts or friction Brakes?			
Are all safety devices inspected prior to using a ladder?			
Does the ladder have a landing platform that serves as a means of interrupting a free fall and as a resting place during long climbs?			
If the ladder is used to ascend to heights exceeding 20 ft (6.1 m), is it constructed with landing platforms for each 30 ft (9.1 m) of height or fraction thereof?			
Is the pitch of the ladder in the range of 75 to 90 degrees with the horizontal?			
Are ladders having a pitch in excess of 90 degrees with the horizontal, prohibited from use?			
Do the rungs on metal ladders have a minimum diameter of three-fourths inch (1.9 cm)?			
Do the rungs on wood ladders have a minimum diameter of 1 1/8 in (2.9 cm)?			
Is the distance between rungs 12 in (30.5 cm) or less and uniform throughout the length of the ladder?			

Employers must establish and implement adequate controls, such as barricades and signs, to prevent non-emergency use of fixed ladders which are meant for fire fighter use and emergency escape only. In some situations, fixed ladders not equipped with cages, landing platforms, ladder safety devices, or other forms of worker protection, may be allowed as a means of access for fire fighters and other emergency personnel, or escape for workers in fire and other emergency situations.

Products and services are provided by one or more insurance company subsidiaries of W. R. Berkley Corporation. Not all products and services are available in every jurisdiction. Certain coverages may be provided through surplus lines insurance company subsidiaries of W. R. Berkley Corporation through licensed surplus lines brokers. Surplus lines insurers do not generally participate in state guaranty funds and insureds are therefore not protected by such funds. Berkley Life Sciences conducts business in California as Berkley LS Insurance Solutions, LLC, a licensed surplus lines broker (License Number 0H44165).

This material is provided to you for general informational purposes only. Coverage afforded under any insurance policy issued is subject to the individual terms and conditions of that policy as issued. Claims scenarios are hypothetical in nature and for illustrative purposes.

Maintaining safe operations and a safe facility in accordance with all laws is your responsibility. We make no representation or warranty, express or implied, that our activities or advice will place you in compliance with the law; that your premises or operations are safe; or that the information provided is complete, free from errors or timely. We are not liable for any direct, indirect, special, incidental or consequential damages resulting from the use or misuse of this information. You are not entitled to rely upon this information or any loss control activities provided by us and you may not delegate any of your legal responsibilities to us. All loss control activities are conducted solely for the purpose of, and in accordance with, our underwriting activities.